

Certificate



No.: 968/K 204.02/18

Product tested	Strong Motion Recorder	Certificate holder	SYSCOM Instruments SA Rue de l'industrie 21 1450 Sainte-Croix Switzerland
-----------------------	------------------------	---------------------------	--

Type designation	NCC2002 with Sensor MS2005+ and Recorder MR2002-SM24-K NCC2002 with Sensor MS2008+ and Recorder MR2002-SM24-K		
-------------------------	--	--	--

Codes and standards	IEC 62138:2004	IEC/IEEE 60780-323:2016 (in extracts)	
----------------------------	----------------	---------------------------------------	--

Intended application	The device complies with the requirements of the relevant standards (Category C acc. to IEC 62138). The assessment was executed in accordance with IEC 60780. Therefore the device can be used in applications up to Category C acc. to IEC 61226.		
-----------------------------	---	--	--

Specific requirements	The instructions of the associated Installation and Operating Manual shall be considered.		
------------------------------	---	--	--

Valid until 2023-05-18

The issue of this certificate is based upon an examination, whose results are documented in Report No. 968/K 204.02/18 dated 2018-05-18.

This certificate is valid only for products which are identical with the product tested.

TÜV Rheinland Industrie Service GmbH
Bereich Automation
Funktionale Sicherheit
Am Grauen Stein, 51105 Köln

Köln, 2018-05-18

Certification Body Safety & Security for Automation & Grid

Dr. R. G. A.

Dr.-Ing. Thorsten Gantevoort